

THERESA AXFORD Superintendent of Schools

District # 3
MINDY CONN

MINDY CON

District # 1
BOBBY HIGHSMITH

District # 2
ANDY GRIFFITHS
Vice-Chairman

District #4
JOHN DICK
Chairman

District # 5
DR. SUE WOLTANSKI

Bid No: ITB 2021009

Name of Bid: HOB School PA Replacement

Post Date: 7/6/2021

Notice Post Time: 5:00 p.m.

**Q&A Response No: 1** 

Q1. Is the district open to any other style clocks to replace the Rauland and Bogen clocks including digital LED style?

A1. We are ONLY replacing the Rauland clocks, the Bogen clocks are all new installs and the model that is there is what we want across the school. We have a Bogen Time server so only Bogen clocks will be compatible once the old intercom has been removed.

Q2. Is it the expectation to re-use the existing interior and exterior speakers?

A2. Yes, we will re-use all existing speakers as long as they are operational. An impedance reading is required in the proposal which will determine whether they work or not.