


THERESA AXFORD
Superintendent of Schools



Members of the Board

District #2
ANDY GRIFFITHS
Chairperson

District # 5
DR. SUE WOLTANSKI
Vice-Chairperson

District # 1
DARREN HORAN

District # 3
MINDY CONN

District # 4
JOHN DICK

Bid No: ITB 2023002

Name of Bid: ADA Access Compliance Renovations

Post Date: 3/6/2023

Notice Post Time: 4:30 p.m.

Q&A Response No: 1

Q1. Could you please provide more details for the Savaria VT-1504 lift including platform size, finishes that will be required for pricing.

A1. Lift should meet the following criteria:

- Platform size – 36"x56"
- Speed- 10 fpm
- Platform material - stainless steel
- Provided fixed ramp matching platform to provide transition from floor to lift platform – min. 32" wide, max slope 1:12 stainless steel finish
- All materials to be rated for exposed marine conditions
- Grab bars to be stainless steel
- Min. 2 year warranty
- Provide dedicated phone line to lift from office.
- Owner to select unit finish color
- Must be anchored to meet code
- Shop drawings required for review.

Q2. Can an alternate "or equal" lift be provided?

A2. Yes

Q3. Is the School providing geo tech report or is contractor responsible?

A3. A Geotech report will be made available after the ITB is awarded.

Q4. Is the School procuring all required testing services? Is the school going to require a load test on the auger piling? Concrete testing?

A4. Testing services are contracted by the School District.