

**THERESA AXFORD**  
Superintendent of Schools



**Members of the Board**

*District # 1*  
**BOBBY HIGHSMITH**

*District # 2*  
**ANDY GRIFFITHS**  
Vice-Chairman

*District # 3*  
**MINDY CONN**

*District #4*  
**JOHN DICK**  
Chairman

*District # 5*  
**DR. SUE WOLTANSKI**

**Bid No: ITB 2023003**  
**Name of Bid: AC Repairs and Replacements**  
**Post Date: 3/10/2023**  
**Notice Post Time: 3:00 PM**

**Addendum No.1**

The following item has been amended from the original release format:

- Replace Section III. B. 4. b. ix. on page 8 with the following (additions in red):

~~AH 4-905A~~ **AH 4-905B**, Carrier Model number 40RM-014-B611HC, Serial number 0303F11476

- Add subsection (n), with the following (additions in red) to Section III. C. 2.:

**n. All replacement AHU's at Key West HS shall be set on 6" legs and angled for proper condensate drainage from both pan and line. All second level AHU's shall have an auxiliary drain pan installed under the unit. New drain pans shall have a high level shut off switch to disable the compressor(s) when condensate overflow occurs.**