


MARK T. PORTER
Superintendent of Schools



Members of the Board

District # 1
BOBBY HIGHSMITH

District # 2
ANDY GRIFFITHS
Chairman

District # 3
ED DAVIDSON

District # 4
JOHN R. DICK
Vice- Chairman

District # 5
RONALD A. MARTIN

Bid No: ITB 2017704
Name of Bid: Condensing Unit Catalog Bid
Post Date: 11/16/2016
Notice Post Time: 2:30 PM

Q&A No1

1. Carrier Corporation no longer offers the following unit in its product line-up 38APD065 (65 tons)
 - a. We will not be able to prove a price for this unit. Please confirm this will not disqualify our bid.
Bid will not be disqualified, list recommended unit or units for that size.
2. Carrier Corporation does not offer a factory mounted BACnet communication card on all units - (6 tons through 20 tons – 38AUZ07 through 38AUD25)
 - a. We will not be able to prove a price for this option. Please confirm this will not disqualify our bid.
Bid will not be disqualified, note in proposal and offer pricing for nonfactory mounted BACnet communication card or translator.
3. Carrier Corporation highly recommends factory start-up on all units larger than 25 tons (25 tons through 130 tons – 38APD025 to 38APD130) to ensure proper performance.
 - a. Please amend the bid document to include this option/recommendation if desired by Monroe County Schools.
If factory start-up is required or recommended include this in your unit price and note it in your proposal.
4. Coatings are called for the coil only – It is our recommendation (due to environment) to coat the entire cabinet and all exposed metals.
 - a. All prior Monroe County School project have required cabinet coating, please amend the bid documents if this is required.
Price as specified in the bid document.