STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC/PRIVATE SCHOOL INSPECTION REPORT

PURPOSE:
- [x] ROUTINE
- [ ] REINSPECTION
- [ ] CONSTRUCT.
- [ ] CHANGE OF OWNER
- [ ] COMPLAINT
- [ ] CONSULTATION
- [ ] QA SURVEY
- [ ] EPIDEMIOLOGY
- [ ] PREOPENING
- [ ] OTHER _____

TYPE:
- [x] 12 Private School
- [ ] 13 Public School
- [ ] 22 Charter School
- [ ] 23 Vocational School
- [ ] 24 College/University
- [ ] Other _____

NAME OF SCHOOL Gerald Adams Elementary
ADDRESS 6868 College Road CITY Fort Myers
OWNER M.C.S.B. ZIP 33840
PERSON IN CHARGE _____ PHONE 239-694-[illegible]

BEGIN	END
(illegible)	(illegible)

DATE: 9/19/13

POSITION: (9:28 K)

PERMIT NUMBER: 34-51-0002

NSL: 537

MAX: 963

MEALS: 274

RESULTS
- [x] Satisfactory
- [ ] Incomplete
- [ ] Unsatisfactory

Correct Violations by
- [x] Next Inspection
- [ ] 8:00 AM on:

DATE: 05 06 07 08 09 10 11 12 13 14

- [ ] OUT OF BUSINESS

This form will serve as a "Notice of Non-Compliance" for any violations noted. Items marked with an "X" are in violation of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period stated. Failure to correct these violations is a violation of Chapter 64E-11, FAC, and may result in administrative fines or other legal action.

SCHOOL SANITATION
- [ ] 1. School Site
- [x] 2. Playground Equipment
- [ ] 3. Athletic Equipment

BUILDINGS
- [ ] 4. Construction
- [x] 5. Maintenance & Repair
- [ ] 6. Lighting/Foot-Candles
- [x] 7. Heating, Ventilation, A/C
- [ ] 8. Natural Ventilation
- [ ] 9. Mechanical Ventilation

SANITARY FACILITIES
- [ ] 10. Provided/Accessible
- [x] 11. Cleanliness & Repair
- [ ] 12. Toilet Facilities
- [ ] 13. Separation of Sexes
- [ ] 14. Fixture Ratio
- [x] 15. Handwash Facilities
- [ ] 16. Showers/Fixtures
- [ ] 17. Shower Water Temp.

WATER SUPPLY
- [ ] 18. Installed/Operated/Maintained
- [ ] 19. Drinking Fountains
- [ ] 20. Approved Source

LIQUID/SOLID WASTE
- [ ] 21. Sewage Disposal
- [ ] 22. Solid Waste

VECTOR/VERMIN CONTROL
- [ ] 23. Infestation/Control
- [ ] 24. Brush/Trash
- [ ] 25. Water Collection/Drainage

SAFETY
- [ ] 26. First Aid Kit

FOOD
- [ ] 27. Food Insp. Rpt.

OTHER
- [ ] 28. _____
- [ ] 29. _____

ITEM NUMBERS | **COMMENTS AND INSTRUCTIONS** (continue on attached sheet)

#2 Cracked plastic slide & cracked plastic bridge on playground. Areas in gym need repair or removed on 3-5yo playground. Repair
#5 Remove spill from outdoor covered pavilion by portables
#5 Repair/replace rusted front panel on gate from Pre-K playground (by fenced playarea for 3-5y.o.)
#7 Repair or replace basin restrooms 35A-D in pod II (Repeat)
#11 chipped floor tile in hallway of pod I. Repair/replace.
#15 Need soap at sinks: Grade 4 Boys restroom & Grade 2 ft.
#15 Need paper towels at Kinder RR, 3SB, & 3SD. (common)

HEALTH DEPARTMENT INSPECTOR: Brandee Pardy PHONE: 239-690-6076

COPY OF REPORT RECEIVED BY: X [illegible] DATE: 9/19/13

DH 4030, 01/05 (Obsoletes Previous Editions)

ESTABLISHMENT/FACILITY